



Engineering Testing and Inspection Service  
Established 1949

Artistic Pavers, Inc.  
c/o Essig Pools, Inc.  
120 N.E. 179<sup>th</sup> Street  
Miami, Fl. 33162  
Attn: Dan Essig


March 24, 2003

Re: Paver Brick Freeze-Thaw Testing: ASTM C 67  
50 Cycles  
7 Samples

Attached are the results of the "Paver Brick Freeze-Thaw Testing", done by our subconsultant, Applied Construction Technologies, Inc. in Cleveland, Ohio. Note that 7 paver samples were used for this test.

A total of 50 freeze-thaw cycles were completed on all seven of the submitted samples with no measurable weight loss or cracking, whereas the pavers tested meet the requirements of ASTM-C-67.

If you have any questions or comments regarding the contents of this report, please do not hesitate to contact this office.

Respectfully submitted,  
**WINGERTER LABORATORIES, INC.**  
<sup>3/24/2003</sup>  
Donald J. Flood Jr., P.E.  
Florida Registration No. 44847

cc: File  
Attachments: As Noted  
Charges: Lump Sum

WLI Order No. 03-1168

1

1820 N.E. 144th St. • P.O. Box 611450 • North Miami, FL 33261-1450 • (305) 944-3401 • 1-800-345-SOIL • Fax: (305) 949-8698

Broward: (954) 764-0472 • Dispatch Fax: (305) 949-1328

STEEL • CEMENT • CONCRETE • PAVEMENT INSPECTIONS • TEST BORINGS • SPECIFICATIONS • CONSULTATIONS

Florida Certificate # F-614